

WSP

Munkerud barnehage

1005775

01

05.10.2026

Snorre Johanson

SJ

06.10.2026

Finn-Arvne Hagfonn

FAH

ROMSKJEMA

Dato:

30.09.2026

06.10.2025

Utskrift:06-10-26

ROMSKJEMA

Munkerud barnehage

ROMNR	ROMNAVN	ETG	BLOKK	AREAL NETTO m2	HØYDE m	VOLUM m3	KOMENTAR
10001	Fingarderobe	1		44.6	3.00	134	
10001	Grovgarderobe	1		35	3.00	105	
10002	HCWC	1		5.4	3.00	16	
10003	Spis	1		41.3	3.00	124	
10004	Kjøkken	1		20.3	3.00	61	
10005	Tema kretsløp	1		17	3.00	51	
10006	Teknisk	1		19.4	3.00	58	
10007	Tavle	1		4.6	3.00	14	
10008	Renhold	1		9.3	3.00	28	
10009	Matbod	1		2.1	3.00	6	
10010	Trapp	1		20	3.00	60	
10012	Gang	1		8.5	3.00	26	
10013	HCWC	1		6.5	3.00	20	
10014	Dame garderobe	1		12.5	3.00	38	
10015	Dusj	1		2	3.00	6	
10016	Lager	1		7.7	3.00	23	
10017	Herre garderobe	1		8	3.00	24	
10018	WC	1		1.7	3.00	5	
10019	Toaletter	1		6.8	3.00	20	
10020	Stellerom	1		7.9	3.00	24	
10021	Tema ,Hvilerom	1		14.1	3.00	42	
10022	Avdeling	1		32.1	3.00	96	
10023	Tema	1		13.8	3.00	41	
10024	Avdeling	1		32.1	3.00	96	
20001	trapp	2		20	3.00	60	
20003	Bildegalleri	2		13.7	3.00	41	
20005	WC	2		1.9	3.00	6	
20006	WC	2		1.9	3.00	6	
20007	Pauserom	2		30.8	3.00	92	
20008	Kontor	2		16.9	3.00	51	

ROMSKJEMA
Munkerud barnehage

ROMNR	ROMNAVN	ETG	BLOKK	AREAL NETTO m2	HØYDE m	VOLUM m3	KOMENTAR
20009	Møte 1	2		9	3.00	27	
20010	Arbeid	2		16.5	3.00	50	
20011	Sittested/grovmotoris	2		47	3.00	141	
20012	Fingarderobe	2		39.7	3.00	119	
20013	Møte 2 ,fordypning	2		16.8	3.00	50	
20014	Avdeling	2		32.1	3.00	96	
20015	Tema , forming	2		13.8	3.00	41	
20016	Avdeling	2		32.1	3.00	96	
20017	Spis	2		56.5	3.00	170	
20018	BK	2		2.2	3.00	7	
20019	Kjøkken	2		23.6	3.00	71	
20020	Matbod	2		5.1	3.00	15	
20021	Fingarderobe	2		28.6	3.00	86	
20022	Avdeling	2		31.5	3.00	95	
20023	Tema ,Hvile	2		13.7	3.00	41	
20024	Avdeling	2		31.2	3.00	94	
20025	Stellerom	2		8.1	3.00	24	
20026	Toaletter	2		6.8	3.00	20	
20027	HCWC	2		5.1	3.00	15	
20028	Stellerom	2		7.9	3.00	24	
20029	Toaletter	2		6.9	3.00	21	
SUM				892		2676	

ROMSKJEMA

Munkerud barnehage

ROMNR	ROMNAVN	VENTILASJON											DIM GRUNNL. LUFTMENGDE		
		ANTALL Personer stk	LUFTMENGDE For.Pers m3/h	For.Matr. m3/h	Pers+Matr. m3/h	Areal m3/h	TILLUFT m3/h	FRALUFT m3/h	m3/m2	ANTALL VEKSL. stk/h		SYSTEM NR	Person l/s/pers	Matr. l/s/m2	AREAL m3/h/m2
10001	Fingarderobe	26	655	241	896		730	125	16.4	5.5	< P+M	102/003 eks	7	1.5	
10001	Grovgarderobe	20	504	189	693		850	1050	24.3	8.1		360.101	7	1.5	
10002	HCWC			29	29			100	18.5	6.2		.003 eks	7	1.5	
10003	Spis	40	1008	223	1231		950	950	23.0	7.7	< P+M	360.103	7	1.5	
10004	Kjøkken	2	50	110	160		430		21.2	7.1		360.104	7	1.5	
10005	Tema kretsløp			92	92		300	300	17.6	5.9		360.105	7	1.5	
10006	Teknisk			105	105		400	400	20.6	6.9		Aksialvifte	7	1.5	
10007	Tavle			25	25			110	23.9	8.0		360.104	7	1.5	
10008	Renhold	1	25	50	75			160	17.2	5.7		360.104	7	1.5	
10009	Matbod			11	11			160	76.2	25.4		360.104	7	1.5	
10010	Trapp			108	108	100					< P+M	360.102	7	1.5	5
10012	Gang			46	46						< P+M	360.02 eks	7	1.5	
10013	HCWC			35	35						< P+M	360.02 eks	7	1.5	
10014	Dame garderobe	5	126	68	194						< P+M	360.02 eks	7	1.5	
10015	Dusj			11	11						< P+M	360.02 eks	7	1.5	
10016	Lager			42	42						< P+M	360.02 eks	7	1.5	
10017	Herre garderobe	2	50	43	94						< P+M	360.02 eks	7	1.5	
10018	WC			9	9						< P+M	360.02 eks	7	1.5	
10019	Toaletter	2	50	37	87			100	14.7	4.9		360.102/211	7	1.5	
10020	Stellerom	2	50	43	93						< P+M	360.02 eks	7	1.5	
10021	Tema ,Hvilerom	7	176	76	253		300	300	21.3	7.1		360.121	7	1.5	
10022	Avdeling	18	454	173	627		650	650	20.2	6.7		360.122	7	1.5	
10023	Tema	7	176	75	251		300	300	21.7	7.2		360.123	7	1.5	
10024	Avdeling	18	454	173	627		630	630	19.6	6.5		360.124	7	1.5	
20001	trapp			108	108	100		200	10.0	3.3		360.102/211	7	1.5	5
20003	Bildegalleri			74	74						< P+M	360.02 eks	7	1.5	
20005	WC			10	10						< P+M	360.02 eks	7	1.5	
20006	WC			10	10						< P+M	360.02 eks	7	1.5	
20007	Pauserom	15	378	166	544						< P+M	360.02 eks	7	1.5	
20008	Kontor	3	76	91	167						< P+M	360.02 eks	7	1.5	

ROMSKJEMA

Munkerud barnehage

ROMNR	ROMNAVN	VENTILASJON													
		ANTALL	LUFTMENGDE							ANTALL		SYSTEM	DIM GRUNNL. LUFTMENGDE		
		Personer stk	For.Pers m3/h	For.Matr. m3/h	Pers+Matr. m3/h	Areal m3/h	TILLUFT m3/h	FRALUFT m3/h	m3/m2	VEKSL. stk/h			NR	Person l/s/pers	Matr. l/s/m2
20009	Møte 1	5	126	49	175						< P+M	360.02 eks	7	1.5	
20010	Arbeid	6	151	89	240						< P+M	360.02 eks	7	1.5	
20011	Sittested/grovmotoris	18	454	254	707		950	100	20.2	6.7		360.211	7	1.5	
20012	Fingarderobe	18	454	214	668			450	11.3	3.8	< P+M	360.217/219	7	1.5	
20013	Møte 2 ,fordypning	8	202	91	292		300	300	17.9	6.0		360.213	7	1.5	
20014	Avdeling	18	454	173	627		650	650	20.2	6.7		360.214	7	1.5	
20015	Tema , forming	7	176	75	251		300	300	21.7	7.2		360.215	7	1.5	
20016	Avdeling	18	454	173	627		650	650	20.2	6.7		360.216	7	1.5	
20017	Spis	28	706	305	1011		950	950	16.8	5.6	< P+M	360.217	7	1.5	
20018	BK			12	12			100	45.5	15.2		360.219	7	1.5	
20019	Kjøkken	2	50	127	178		650		27.5	9.2		360.219	7	1.5	
20020	Matbod			28	28			100	19.6	6.5		360.219	7	1.5	
20021	Fingarderobe	18	454	154	608			350	12.2	4.1	< P+M	360.211	7	1.5	
20022	Avdeling	18	454	170	624		650	650	20.6	6.9		360.222	7	1.5	
20023	Tema ,Hvile	7	176	74	250		300	300	21.9	7.3		360.223	7	1.5	
20024	Avdeling	18	454	168	622		650	650	20.8	6.9		360.224	7	1.5	
20025	Stellerom	2	50	44	94						< P+M	360.02 eks	7	1.5	
20026	Toaletter	2	50	37	87			100	14.7	4.9		360.211	7	1.5	
20027	HCWC			28	28			100	19.6	6.5		360.211	7	1.5	
20028	Stellerom	2	50	43	93						< P+M	360.02 eks	7	1.5	
20029	Toaletter	2	50	37	88			100	14.5	4.8		360.211	7	1.5	
SUM		365	9198	4817	14015	200	11590	11385							